

ADDENDUM NO. 1

Project: 14th Avenue South Reconstruction – 17th Street S. to 13th Street S.
Client: The City of Cranbrook
Date: May 22, 2013
File: 0956.0014.22

This Addendum is issued prior to Tender Closing Date, in accordance with the Tender Documents and shall be considered an integral part of the Contract Documents, read together with the Drawings, Specifications and Addenda previously issued and with all subsequent Addenda.

1. Correction - Reference drawing E1, STREET LIGHT PLAN PHASE 3, revision 2, Issued for Tender, dated 13/05/08, Note 8.

Note 8 incorrectly states the requirement for the Contractor to supply photocells for luminaires. The proposed pole mounted luminaires to be installed from 17th St. To 13th St. S. do not require photocells. The proposed luminaires will connect to existing street lights previously installed and currently operating on an existing photocell.

2. Clarification – Reference Schedule of Quantities and Prices, OPTIONAL WORK, DIVISION 26 – ELECTRICAL, Section 26 56 01 – Roadway Lighting, Item 1.0.

Replacement luminaires for existing power pole davit mounted luminaires between 10th St. S. and 1st St. S will require individual photocells to be supplied and installed.

URBAN SYSTEMS LTD.



Rob Mogentale, ASCT
 Contract Administrator

Cc: Jaime Hodge, P.Eng., City Engineer, City of Cranbrook
 Eric Sharpe, Project Manager, City of Cranbrook
 /rm

Please ensure receipt of this Addendum is acknowledged on the online Bid Form.