



saving you energy

Electrical Addendum

Project Name	City of Cranbrook Canadian Rockies International Airport Lighting Upgrade
Prism Project No.	2019207
Addendum No.	E-1
Prepared By	Andrew Munro
Date Issued	July 8, 2020

Engineer Seal

This Addendum forms part of the contract documents and is to be read, interpreted and co-ordinated with all other parts. The cost of all work contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Form of Tender.

1. SECTION 26 57 00: SCHEDULES FOR LIGHTING: NEW LUMINAIRES AND PRODUCT REPORT

1.1 Screening Room New Luminaire: Type 'See Specifications'

- 1.1.1 The following product is accepted as an equivalent and accepted to bid.
- 1.1.2 LEDALITE Model #EL-D-S-L-835-34-Q-G-04/08-D-E-R-W-W-04-R1.

1.2 Type LU-B3s

- 1.2.1 Delete reference to Type LU-B3s.
- 1.2.2 Revise to be Type LU-B2s with the following description:
- 1.2.3 "40W LED 4' Utility Striplight: Nominal 40W 4' long linear LED striplight luminaire with frosted ribbed acrylic lens and high brightness solid state LEDs providing 3,700 to 4,200 delivered lumens. Surface or suspension mounted."
- 1.2.4 Accepted Products:
 - CREE LS4-40L-35K-10V
 - DAY-BRITE FSS-4-40L-835-UNV-DIM
 - PEERLESS ELECTRIC NSL-RA-4-40-35K-W-MV
 - Or accepted equivalent

END OF ADDENDUM E-1