

## CITY OF CRANBROOK

### INVITATION TO TENDER RCMP PUBLIC SPACES CCVE CRA2022-T-003

#### ADDENDUM #1

Date: May 18, 2022

This Addendum is issued to clarify questions that have arisen as follows:

Q1. Please confirm the materials that are being supplied by PTSS.

**A1. PTSS will not be providing any equipment.**

Q2. The camera naming on the drawing does not seem to coincide with the scope of work, please clarify.

**A2. The number of the cameras is as per the drawings.**

Q3. Is the camera cabling to be installed in EMT, or are we to use the J hook system depicted on the drawing E-2?

**A3. EMT must be used where cabling is required to be surface mounted or is accessible to the public. J-hooks may be used inside the building in accessible ceilings.**

Q4. On page 1 of the scope of work there is reference to the installation of 15 cameras, (5 existing and 10 new) could you update the drawing to reflect which cameras are existing?

**A4. There are 15 cameras, as per the drawings – all of them are new.**

Q5. Are the existing cameras that are to be replaced, IP cameras or analog?

**A5. Analog assumed.**

Q6. Would the existing cameras require recabling?

**A6. Yes.**

Q7. Page 4 of the scope of work references the installation of 9 cameras CP01-CP09, please verify the number of cameras.

**A7. There are 15 cameras.**

Q8. Page 20 of the scope of work references the installation of network cables to the workstations and monitor wall display. They are not noted on the drawing. Please clarify where these are located, or if they are outside the scope of work.

**A8. The scope of work is noted in the drawings, workstation and monitors are existing.**

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.**

Melissa Smith CPA, CA  
Financial Services Manager  
City of Cranbrook